

कार्यालय नगर पालिका परिषद कोसीकला (मथुरा)

पत्रांक


दिनांक 13.4.2022

WHOM IT MAY CONCERN
TEST CERTIFICATE

सेवा में,
सरस्वती विद्या मन्दिर
गोवर्धन रोड, छाता

no	Test Conducted	Test Result	Desirable	Requirement(Is : permissible Limited in the absence of alternate source.	Test Method
1.	pH	7.4	6.5x8.5	No Relaxation	IS:3025 P-11
2.	Colour (Hazen Unit)	<5	5	25	IS:3025 P-4
3.	Taste	Agreeable	Agreeable	-	IS:3025 P-7
4.	Turbidity (NHU)	1.2	5	10	IS:03025 P-10
5.	Odour	Unobjectionable	Unobjectionable	-	IS:3025 P-5
6.	Chloride as Cl, (mg/l)	65	250	1000	IS:3025 P-32
7.	Total Hardness as CaCO ₃ (mg/l)	351	300	600	IS:3025 P-21
8.	Total Iron as Fe. (mg/l)	0.06	0.3	1.0	IS:3025 P-53
9.	Residual free chlorine (mg/l)	Nil	0.2	-	IS:3025 P-26
10.	Fluoride as F, mg/l	1.25	1.0	1.5	APHA20 th Ed.
11.	Total Cliform MPN/100 ml	Nil	-	10	IS: 1622
12.	E Coil 10 ml	Nil	-	Nil	IS : 1622

Remarks : The sample of water can be used for drinking purpose.


अवर अभियन्ता (जल)
कोसीकला (मथुरा)
नगर पालिका (मथुरा)